
TO SYSTEM PIPING
SUPPORTED INDEPENDENTLY
BY HANGERS.
FROM SYSTEM PIPING
SUPPORTED INDEPENDENTLY
BY HANGERS.
TRIPLE DUTY VALVE
FLEX CONNECTOR
BUTTERFLY VALVE
TVI HYDRONIC
INDICATOR SYSTEM
(4 PORT)
FLEX CONNECTOR
OSHA/ANSI COUPLER GUARD
SUCTION DIFFUSER
WITH STRAINER
ANCHOR BOLTS
SUPPORT FOOT
(FIELD FABRICATED)
PUMP BASE MUST BE GROUTED
ISOLATED AS NEEDED
CONCRETE PAD
TIED TO FINISHED FLOOR
FOUNDATION MUST WEIGH AT
LEAST 2.5 TIMES WEIGHT OF PUMP
FINISHED FLOOR